

Review Article

LITERATURE SURVEY OF FLUE GAS TREATMENT UNIT FOR PACKAGED GASOLINE GENERATORS.

ABSTRACT

A literature survey of Flue Gas Treatment Unit for Packaged Gasoline Generators is reported. Due to shortfall in power supply from National Grid of most developing nations, most businesses relied on package generators for electrical power supply for their economic activities. Flue gases containing CO, CO₂, SO₂ and NO_x were being released into the environment by these fossil fired package generators. The CO is known to be detrimental to health of living beings and at the same time ozone layer depletive. On the other hand, the CO₂ has been contributing to the green house effects. These militating dangers/risks arising from the usage of these package generators strongly stimulated this study. The global position on legislation, regulation and control of the emission of flue gases into the atmosphere has been articulated. Results of in-depth investigations by researchers into the methods/techniques of capturing CO, CO₂, SO₂ and NO_x from the flue gases have been highlighted. This study shows that incorporating the capturing techniques for CO, CO₂, SO₂ and NO_x into the design and construction of the package gasoline generators will no doubt go a long way in keeping our environment healthy, safe and secured.

KEY WORDS: Flue Gas Treatment Unit, Emission Limit Values, Package Generators.

INTRODUCTION

By the end of the 20th century it was widely accepted that carbon dioxide and several other gases are involved in physical and chemical processes in the earth's upper troposphere and stratosphere that may result in global climate change. Arrhenius in 1896 forecasted rising global temperatures as a result of fossil fuel combustion. So-called green house gases (GHG), most importantly Carbon Dioxide (CO₂), Methane (CH₄) and Nitrous Oxide (N₂O) trap the outgoing solar radiation that is reflected by the earth's surface, which leads to global warming.[1] Although the most abundant greenhouse gas in the atmosphere is water causing approximately 2/3 of the greenhouse effect, the result of increasing concentrations of GHGs that cause the other approximately 1/3 is referred to as the "enhanced greenhouse effect", or, since it is primarily the result of human activities, the "anthropogenic greenhouse effect".[1] Consequent on the foregoing therefore, various regulations have been put into place to arrest this green house effect.

In order for society to meet up with its energy demand, various forms of energy sources have been harnessed by mankind. Most of these power plants are fired by fossil fuels which give CO₂, CO, SO₂, NO_x as by- products of combustion amongst others. CO₂ in particular has been identified as the most important green house gas. Various efforts are being made and several actions are being taken by the global regulating bodies to control and limit the emission of CO₂ and other green house gases. These efforts that focus on design /capture concept are not extended to the gasoline package generators. In the developing countries, the package generators which are actually designed as standby generators now play the function of source of main power supply for businesses and homes. The attendant implications are that CO₂, CO, SO₂ and NO_x are being indiscriminately emitted into the environment to the detriment of health and global warming which could result from the greenhouse effect. Consequent on the foregoing some action plan is required to arrest this indiscriminate pollution of the environment arising from the gasoline package generators' emissions among others. This literature survey therefore seek to articulate the global

legislation framework in place, research efforts and actions taken so far to control the emission of flue gases into the atmosphere. Here lies the justification for this review.

THE PACKAGED GASOLINE GENERATOR AND FLUE GASES

Generators vary in size and complexity depending on rated output power and purpose.

Generators could be classified according to source of energy hence we have thermal generators, geothermal generators, hydro generators and solar generators. Also generators could be classified based on the source of fuel: such generators include natural gas generators, gasoline generators, diesel generators, brown gas generators and wood gas generators among others. Such package generators are variously referred to as portable generators, portable electric generators, portable power generators, home standby generators, commercial generators and marine generators.^[2] The power range for a variety of these package generators varies from about 800watts to 15 kilowatts.^[2] These generators could be classified according to manufacturers and marketing outfit. A few of such names include: Honda, Yamaha, Norwall power systems, Binatone, Firman, Elemax and Tiger.

The energy and power delivery to the economies of the developing nations has been dwindling over the years. The quality of power generated, that is supply relative to demand has been on the decline, even in the face of new power stations coming on stream the National Grid. This short fall in meeting the National demand has been so severe that virtually all serious business concerns have to procure one form of generating set or the other in order to guarantee the smooth continuity of their businesses.^[3]

The brand of these generators that are fossil fuel fired release flue gases into the environment. Flue Gas has been defined as gas that exits to the atmosphere via a flue which may be a pipe, channel or chimney for conveying combustion from a fireplace, oven, boiler or steam generator.^[4] Flue gases are produced when coal, fuel oil, natural gas, wood or any other fuel is combusted in an industrial furnace or boiler, a steam generator in a fossil fuel power plant or other combustion sources.^[4] These gases are treated as pollutants. Flues can be referred to as "stacks", and they may be found in the form of chimneys, ducts, or simple pipes. Large amount of flue gases are generated around the world on daily basis, with heavy industry and the power industry in particular being responsible for a huge percentage of the total generated. The contents of flue gases are quite variable. The medium being burned can contribute a number of different compounds, and the conditions under which combustion is occurring can also generate more or less emissions. Incomplete combustion at low temperatures or in poorly managed facilities, for example, tends to generate more pollution. Components of flue gases include: water vapor, carbon dioxide, nitrogen, particulates, oxygen, carbon monoxide, nitrogen oxide, hydrocarbons, and sulfur oxide. Some of these compounds are potentially harmful for the environment, making these gases an issue of concern among environmental advocates. Flue gases can also be hazardous for human health, as might occur if they were trapped in an air inversion which pinned them close to the ground for several days, forcing people in the area to inhale hazardous pollutants which could damage their lungs. There are a number of ways in which flue gases can be controlled, and the processes which produce flue gases are often heavily regulated to force emissions levels down. One of the best methods is to avoid generating them at all, either by using alternative technology, improving plant efficiency levels, or studying ways in which operating conditions could be improved to reduce the production of combustion by-products. Gases which cannot be prevented can be trapped using filters and scrubbers which clean the air coming out of flues so that when it is released into the environment, it contains primarily harmless components. Scrubbing flue gases can even be profitable for a savvy company. For example, the food industry is willing to pay for purified carbon dioxide extracted from flue gases.^[5]

LEGISLATIONS/REGULATIONS ON POLLUTION

It is not possible to produce comparative tables with emission limit values for the two regions (that is, EU and USA) because emission limit values are defined in different ways. In the EU, values are defined in terms of mg/nm³, whereas in the US values are expressed as nanograms per joule heat input. For the EU, emission limit values are defined in Annex III-VII in the Directive 2001/80/EC on the limitation of emissions of certain pollutants into the air from large combustion plants (the "LCP directive"). Emission limits are defined for SO₂, NO_x and dust. Furthermore, there are provisions for combustion plants co-incinerating waste in Annex II of the directive 2000/76/EC of 4 December 2000 on the incineration of waste. For the USA, emission limit values related to combustion plants are given in Title 40 (Protection of Environment), Part 60 (Standards of Performance for New Stationary Sources) in subparts Da, Db, Dc and GG.

The Standard (Section S60.43) for Sulfur Dioxide (SO₂) stipulates that:

- (a) On and after the date in which the performance test required to be conducted by S60.8 is completed, no owner or operator subject to the provision of this subpart shall cause to be discharged into the atmosphere from any affected facility any gases that contain SO₂ in excess of: (1) 340ng/J heat input (0.8lb/MMBtu) derived from liquid fossil fuel or liquid fossil fuel and wood. (2) 520 ng/J heat input (1.2 lb/MMBtu) derived from solid fossil fuel or solid fossil fuel and wood residue.

- (b) When different fossil fuels are burned simultaneously in any combination, the applicable standard (in ng/J) shall be determined by proration using the formula:

$$P_{SO_2} = [y(340) + z(520)] / (y + z)$$

Where P_{SO₂} = prorated standard for SO₂ when burning different fuels simultaneously in ng/J heat input derived from all fossil fuels or from all fossil fuels and wood residue fired.

Y = percentage of total heat input derived from liquid fossil fuel and

Z = percentage of total heat input derived from solid fossil fuel.

According to the Sulfur Content of Liquid Fuels Directive 1999/32/EC on Reduction of Certain Liquid Fuels (26th April 1999), Sulfur content of gas oil not to exceed 0.1 %. Member states shall take all necessary steps to ensure that as from 1 January 2003 within their territory heavy fuel oils are not used if their sulfur content exceeds 1.0% by mass. Alternatively, where the emissions of sulfur dioxide from the plant are less than equal to 1700mg/nm³ at an Oxygen content in the flue gas of 3% by volume on a dry basis. The reference method adopted for determining the sulfur content shall be that determined by:

- a) ISO Method 8754 (1992) and PrEN ISO 14596 for heavy oil and marine gas oil
b) EN Method 24260 (1987) ISO 8754 (1992) and PrEN ISO 14596 for gas oil.

The arbitration method will be PrEN ISO 14596. The statistical interpretation of the verification of the sulfur content of the gas oil used shall be carried out in accordance with ISO Standard 4259 (1992).[6]

CHINA'S "TWELFTH FIVE-YEAR PLAN" ON AIR POLLUTION PREVENTION

On 5th December 2012, Ministry of Environmental Protection (MEP), National Development and Reform Commission and Ministry of Finance jointly issued a "12th five-year plan on Air Pollution and Control in key regions" as approved by the China's State Council. The three key regions are: Beijing-Tianjin-Hebei, Yangtze River Delta and Pearl River Delta and 10 city clusters, involving 19 provincial level jurisdictions and 117 cities. These areas cover only 14% of the country's land area, but accounts for nearly half (48%) of the country's population, 71% of the nation's GDP and 52% of the country's coal consumption. The air pollutants emission level is 2.9 to 3.6 times higher than the nation's average.

- i) The Plan sets ambient concentration targets for the first time, thus:

TABLE 1. Ambient Concentration Targets

Ambient Air Quality	PM ₁₀	SO ₂	NO ₂	PM _{2.5}	PM _{2.5} (In 3 Key Regions)
Concentration Targets	10%	10%	7%	5%(Expected Target)	6%(Binding Target)

- ii) The Plan sets more ambitious emission targets in key regions than the national targets

TABLE 2. Emission Targets For Nation and Key Regions.

Total Emission Reduction Targets for:	SO ₂	NO _x	Industrial PM
National Targets By 2015	8%	10%	No target
Targets in Key Regions By 2015	12%	13%	10%

If the plan is successfully implemented, it will lead to an estimated SO₂ emission reduction of 2.28million tons/year, NO_x emission reduction of 1.48million tons/year and PM emission reduction of 1.48 million tons/year and VOCs emission reduction of 1.525 million tons/year. And it is expected to bring over \$317 Billion (2 trillion Yuan RMB) society benefit.[7]

RESEARCH EFFORTS OF MINIMIZING SO₂, NO_x, CO₂ and CO POLLUTION

Promoting effect of SO₂ on selective catalytic reduction (SCR) of NO by NH₃ over a CuO/Al₂O₃ catalyst sorbent has been investigated.^[8] Transient experiment, x-ray photoelectron spectroscopy (XPS) insitu Drift, NH₃-TPD and temperature-programmed reduction (TPR) were used to evaluate the promoting mechanism. Ammonia oxidation experiments and TPR in H₂ suggest that sulfation of the catalyst sorbent weakens the catalyst's oxidation ability and inhibits NH₃ oxidation to NO in the process of SCR, which may be another main promoting effect of SO₂ on SCR.[8] Also, liquid-like nanoparticle organic hybrid materials (NOHMs) consisting of silica nanoparticles with a grafted polymeric canopy were synthesized. Because SO₂, which is another acidic gas found in flue gas, would also interact with NOHMs, this study was designed to investigate its effect on CO₂ capture in NOHMs. In particular, CO₂ capture capacities as well as swelling and CO₂ packing behaviours of NOHMs were analyzed using thermogravimetric analysis and RAMAN and attenuated total reflectance (ATR) Fourier transform infrared (FTIR) spectroscopes before and after exposure of NOHMs to SO₂. It was found that the SO₂ absorption in NOHMs was only prominent at high SO₂ levels (I.E 3010 PPM; P_{Tot} = 0.4mpa far exceeding the typical SO₂ and CO₂ for the same absorption sites (i.e ether and amine groups) resulted in a decreased CO₂ captured capacity of NOHMs.[9] on the other hand, CO₂ capture and storage (CCS) has the potential to develop into an important tool to address climate change. Given society's reliance on fossil fuels, widespread adoption of CCS appears indispensable for meeting stringent climate targets need to be complemented with air capture, removing CO₂ directly from the atmosphere. The only feasible techniques involve either absorption or adsorption on a sorbent. With such techniques, energy is required only to regenerate the sorbent. This regeneration process operates on the sorbent mass, which scales with the mass of the CO₂ captured rather than the much larger mass of the air. Carbon-free renewable and nuclear energy resources are theoretically sufficient for human kind's energy needs. It is unclear however whether these resources can be deployed rapidly and widely enough to overcome socio-political obstacles related to costs, environmental impact and public acceptance. Point-source CO₂ capture and storage (CCS) allows for continued use of fossil fuels in power plants and in steel and cement production while largely eliminating their CO₂ emissions.[10] The removal of CO₂ from flue gases is done with the desire to reduce

203 greenhouse emissions among other factors. The Econoamine FG Process is one of the
204 plants that recovers CO_2 from flue gases, using an inhibited 30weight percent of
205 Monoethanolamine (MEA) solution. It recovers 85-95% of the CO_2 in the flue gas. The only
206 commercial absorbents active enough for recovery of dilute CO_2 from atmospheric pressure
207 gas are monoethanolamine and other primary amines.[11]

208 In similar vein, an experimental study on NO_x removal from a simulated diesel engine was
209 carried out using dielectric barrier discharge (DBD) reactor for various electrode shapes to
210 improve the removal efficiency. The electrode shapes employed in the experiment were a
211 plane, a trench and multipoint configurations. The 0.5mm thickness of alumina
212 ($\text{Al}/\text{sub}2/\text{O}/\text{sub}3/$) dielectric barrier was produced on a plane electrode via a powder flame
213 spray. The DBD reactor with multipoint electrodes was applied to 20KVA diesel engine
214 generator exhaust gas treatment. The contained $\text{NO}_x = (\text{NO} + \text{NO}/\text{sub}2/)$ was abated from 70
215 to 40 ppm at no load to the generator and from 340 to 300 ppm at 50A load. The energy for
216 NO_x removal is obtained to 32g/KWh.[12]

217 In another development, atmospheric O_3 , CO , SO_2 and NO_v^* were measured at a rural
218 agricultural site in the Yangtze Delta of China.[13] The ratio of CO to NO_v^* was 36
219 (ppbv/ppbv) for the winter and night time measurements. Value for industrialized
220 countries~(10ppbv/ppbv). Where NO_v^* is the sum of NO , NO_2 , PAN, Organic Nitrates, HNO_3 ,
221 and N_2O_5 . The highest value for the ratio of CO to NO_v^* was 30–40ppbv/ppbv and occurred
222 in September-December 1999 and June 2000. The good correlation between CO and the
223 biomass burning tracer CH_3Cl and the lack of correlation with the industrial tracer C_2Cl_4
224 suggest that the burning of biofuels and crop residues is a major source for the elevated CO
225 and possibly for other tracer gases as well. SO_2 to NO_v^* ratio was 1.37ppbv/ppbv. High
226 value of ratio is as a result of use of high sulfur coals in China. The measured SO_2 to NO_v^*
227 ratio and CO to NO_v^* ratio were compared with the respective ratios from the current
228 emission inventories for the region, which indicated a comparable SO_2 to NO_v^* emission
229 ratio, but a large discrepancy for CO to NO_x ratio. The observed CO to NO_v^* ratio was more
230 than 3 times the emission ratio derived from inventories.[13]

231 Also, large eddy simulation (LES) of the gas-second order moment (SOM) of particles
232 model based on the two fluid method coupled with the subgrid-scale (SGS) reaction
233 submodel was applied to investigate SO_2 and NO_x emissions circulating fluidized bed (CFB)
234 combustors. The SGS reaction submodel based on the eddy dissipation concept (EDC)
235 model was developed considering the effect of particles to circulate the SGS reaction rates.
236 The predicted results by the model are in agreement with the experimental data. The flow
237 characteristics including concentration and SOM of particles were analyzed. The simulation
238 results show that the particles including coal and desulfurized particles were sufficiently
239 mixed. The velocity fluctuation of particles was enhanced for the combustion process, and
240 the velocity fluctuation in the axial direction was about twice higher than that in the radial
241 direction. It was observed that the SGS reaction of gas not only improved the homogenous
242 reaction of gas but the heterogeneous reaction also.[14]

243 In another investigation, Iron oxide supported on alumina as a catalyst/absorbent for use in
244 the simultaneous removal of NO_x and SO_x from power plant stack gases is reported. A dry-
245 contacting process underdevelopment would operate under net reducing conditions at
246 temperatures of 370° to 540°C . Iron oxide is converted to the ferrous state. NO is reduced to
247 NH_3 and SO_2 is removed as ferrous sulfide or sulfate. Regeneration with air provides SO_2
248 and reforms Fe_2O_3 . The reduction of SO_2 by CO and H_2 was studied in fixed bed reactors to
249 determine the effects of temperature and of the other reactive components of flue gas except
250 (flyash) on the rate of reaction and the products formed. H_2S and COS react with FeO to
251 form FeS . Under readily attainable conditions, virtually complete removal of sulfur
252 compounds was achieved for gas-phase residence times of about 1 to 10ms. NO and NO_2
253 were also reduced.[15]

254 On a similar note, Iron titanate catalyst ($\text{Fe}_2\text{T}_2\text{O}_4$) is a potential candidate for the substitution of
255 conventional $\text{V}_2\text{O}_5\text{-WO}_3(\text{M}_b\text{O}_3)/\text{T}_2\text{O}_2$ and $\text{Fe}/\text{C}_u\text{-Zeolite}$ catalysts for the selective catalytic

reduction (SCR) of NO_x with NH_3 because of its high SCR activity and N_2 . [16] Also, an Iron titanate catalyst with a crystalline phase, prepared by a co-precipitation method showed excellent activity, stability, selectivity and $\text{SO}_2/\text{H}_2\text{O}$ durability in the selective catalytic reduction of NO with NH_3 in the medium temperature range [17]. Furthermore, a cyclic process is described for removing the oxides of Sulfur from flue gas by absorption at 625°F and then converting the oxides to elemental sulfur by reduction of the spent absorbent. Pilot plant experiments are reported in which a solid absorbent of alkalized alumina in free and baffled fall is used to remove SO_2 and SO_3 from the combustion gas of a pulverized coal-fired furnace. The absorbent is then regenerated by heating with hydrogen or with steam-reformed natural gas. Fly ash does not interfere and attrition is negligible. [18] On the other hand, the effectiveness of limestone and dolomite in removing SO_2 from flue gas can be estimated by thermo-chemical reactions. Both lime and magnesia are shown to be suitable for removing SO_2 from hot flue gas, with lime more suitable than magnesia over the temperature range where furnace conditions and reaction kinetics are likely to be favorable. [19] on the other hand, one of the most important steps in the wet limestone gypsum flue gas desulfurization (WFGD) process is CaCO_3 dissolution, which provides the dissolved alkalinity necessary for SO_2 absorption. Accurately evaluating the CaCO_3 dissolution rate is important in the design and efficient operation of WFGD plants. In the present work, the dissolution of limestone from different sources in South Africa has been studied in a pH-stat apparatus under conditions similar to those encountered in wet FGD processes. The influence of various parameters such as the reaction temperature, ($30 \leq T \leq 70^\circ\text{C}$), CaCO_3 particle size ($25 \leq d_p \leq 63\mu\text{m}$), solution acidity ($4 \leq \text{pH} \leq 6$) and chemical composition were studied in order to determine the kinetics of CaCO_3 dissolution. The results obtained indicate that the dissolution rate increased with a decrease in the particle size and increase in temperature [20]. The industrial flue gas treatment systems and services market is growing at a significant rate, driven by the stringent regulations in developed countries and the rising demand for electricity in the emerging economies. Pollution control can be segmented into: flue gas desulfurization, D_eNO_x , particulate control, mercury control and others (VOCs, dioxins, HCl and HF). The enforcement of federal laws and regulations that mandate the industries to install pollution control equipment have spurred the growth of industrial flue gas treatment systems. [21] In a similar vein, the Global and China flue gas desulfurization system industry is reported. The report firstly introduced flue gas desulfurization basic information included flue gas desulfurization, definition, classification and application among others. It also listed flue gas desulfurization upstream raw materials and downstream analysis and flue gas desulfurization marketing channels. [22] Furthermore, the suitability of a mathematical model for circulating fluidized bed (CFB) coal combustion was investigated. The model predicted the development of tar and other hydrocarbons valuating the agreement between the measured and calculated efficiency. [23] In another development, the comprehensive test results of an ultra-micro Gas Turbo-Generator fed by a mixture of butane and propane gas at the University of Roma was reported. Key indicators of test are: Turbo-Generator rated power ($\sim 10 \text{ KW}$); compressor efficiency ($0.52 \sim 0.77$); fuel consumption ($0.0015 \sim 0.010 \text{ kg/s}$) and turbine inlet temperature ($858 \sim 1137 \text{ K}$). The key limitation was the high fuel consumption which required optimization of the machine in order to reduce the fuel consumption and increase the bearings life time. [24] Also, a management protocol for electrical and thermal loads in housing scheme equipped with co-generative unit and renewable system has been described. This protocol optimally manages the instant power generation from co-generative and renewable devices. [25] A performance report is documented on the economic, technical and environmental feasibility tests on running a 20MW diesel generator on vegetable oil (palm oil). The main constraint identified in this report is the availability and cost of the vegetable (palm) oil. [26] The Malaysian AM cash market prices for palm oil stood at US \$612 per metric Tonne. [27] Also global petrol price in USA stood at US\$0.97 per litre, UK at US\$2.18

309 and Nigeria at US\$0.58 per litre respectively.[28] In the same vein World market gas prices
 310 averaged US\$3.41 per gallon.[29] While Butane gas is priced £16.75 (or \$27.3) per 4.5kg
 311 cylinder and Propane gas £16 (or \$26.08) per 3.9kg cylinder.[30] Also, gasoline
 312 consumption for a 10KVA package gasoline generator stands at 18 litres in 4.5 hours.[31]
 313
 314
 315
 316
 317
 318
 319

320 SUMMARY OF LITERATURE REVIEW

321
 322 **Table 3: Summary of Legislation/ Regulation Review.**
 323

EMISSION LIMIT VALUES (ELV)		EU mg/NM ³	USA ng/J Heat	CHINA ppbv/ppbv
	ELV defined in	Annex III-VII in the Directive 2001/80/EC. Directive 1999/32/EC	Title 40 Part 60 Subparts Da, Db, Dc and GG.	"12 TH 5-year Plan" on Pollution Prevention
SO ₂	Liquid fossil fuel	0.1 by mass	340	10%. National target 2015 = 8%. Target region = 12%
	Solid fossil fuel	1.0% for heavy fuel oils Or for $\leq 1700\text{mg/Nm}^3$ @O ₂ content in flue gas of 3% by volume.	520	
	Combined	For heavy oil and marine gas oil: ISO method 8754 (1992) For gas oil; EN 24260 (1987)	P _{SO2} (see equation 1)	
	NO ₂			7% National target 2015 = 10% Target region = 13%

324 SOURCE: Summary Of Legislation/Regulation Review above.
 325

326 **Table 4. Summary of Capture Methods From Flue Gas**
 327

S/No.	COMPONENTS	REDUCTION METHOD	MATERIALS	AUTHOR'S REFERENCE

				NUMBER
1	SO ₂	Ambient content measured at rural agricultural site	Gas analyzers	[13]
2		Large eddy simulation (LES), Gas-second order moment (SOM) and CFB combustors coupled with sub-grid scale (SGS). (two-fluid method)	Coal and desulfurized particles	[14]
3		A dry contacting process for simultaneous removal of NO _x and SO _x from plant stack.	Iron oxide supported on alumina as catalyst	[15]
4		Cyclic process of removing SO ₂ and SO ₃ by absorption	Absorbent, alkalized alumina in free and baffle fall.	[18]
5		Thermo-chemical reactions using limestone and dolomite	Limestone, dolomite and magnesia	[19]
6		Limestone gypsum absorption	limestone	[20]
7	NO _x	Selective catalytic reduction (SCR) presence of SO ₂ weakens NH ₃ oxidation to NO	NH ₃	[8]
8		Dielectric barrier discharge (DBD) reactor applied to 20KVA diesel engine generator	Al/sub2/O/sub3/ Alumina dielectric barrier	[12]
9		Ambient content measured at rural agricultural site	Gas analyzers	[13]
10		Large eddy simulation (LES) gas-second order moment (SOM) and CFB combustors coupled with sub-grid (SGS). (two-fluid method)	Coal and desulfurized particles	[14]
11		A dry-contacting process for simultaneous removal of NO _x and SO _x from plant stack.	Iron oxide supported on alumina as catalyst	[15]
12		Iron titanate catalyst+V ₂ O ₅ -WO ₃ and Fe/Cu-Zeolite catalyst for SCR of NO _x with NH ₃ .	Iron titanate, Zeolite and NH ₃	[16]
13		Catalytic reduction of NO with NH ₃	SO ₂ /H ₂ O. iron titanate as catalyst.	[17]

14	CO ₂	Nanoparticle organic Hybrid materials (NOHMs) absorption of CO ₂ was affected by the presence of SO ₂ in the flue gas, that is reduction in CO ₂ capture.	Nanoparticle organic Hybrid materials (NOHMs)	[9]
15		Absorption or adsorption	sorbent	[10]
16		Econoamine FG (Absorbents)	MEA	[11]
17	CO	Ambient content measured at rural agricultural site	Biomass burning tracer, CH ₃ Cl; Industrial tracer, C ₂ Cl ₄ .	[13]

SOURCE: Summary from literature review above.

TABLE 5. Alternative/Enhancement Sources to Gasoline Generators

S/No.	ALTERNATIVE/ENHANCEMENT SOURCES TO GASOLINE GENERATORS	FUEL	LIMITATIONS	REFERENCE
1	Micro Gas Turbo Generator at University of Roma	Mixture of Butane and Propane gas	High fuel consumption	24
2	20MW Diesel Generator test	Vegetable (Palm) oil	Cost and availability	26
3	Mathematical Modeling of Biomass Gasification	coal	Flue gas treatment not squarely addressed as primary objective	23
4	Power Quality Management	-	Addressed the efficiency in power usage but silent on flue gas managment	25

SOURCE: SUMMARY FROM LITERATURE REVIEW ABOVE

TABLE 6. Fuel Prices

S/No.	FUEL	PRICE	REFERENCE
1	Gasoline	USA = \$0.97/Litre; UK = \$2.18/Litre and Nigeria = \$0.58/Litre.	[28]
2	gas	US\$3.41 per gallon	[29]
3	Palm oil (vegetable oil)	US\$612 per Metric Tonne	[27]
4	Butane Gas Propane Gas	4.5kg = £16.75 (or \$27.3) 3.9kg = £16 (or \$26.08)	[30]

SOURCE: SUMMARY FROM LITERATURE REVIEW ABOVE

RELATING RESEARCH EFFORTS TO LEGISLATION

Legislations, Standards and Regulations from the EU, USA and China as detailed in Table 3 above are quite comprehensive in the regulating and control of flue gas emissions into the atmosphere. On the other hand, the research and investigations into the process, methodology and strategy for the removal of SO_x , NO_x , CO and CO_2 from flue gases as detailed in Table 4 has been thorough, detailed and thought provoking. From the information in Table 4, it can be seen that [8], [12], [13], [14], [15], [16] and [17] have demonstrated various ways of capturing NO_x from flue gases. In the same vein, from Table 4, [13], [14], [15], [18], [19] and [20] have also demonstrated various ways of capturing SO_2 from flue gases. On a similar note, information on Table 4 show [9], [10] and [11] have captured CO_2 from flue gases using various ways. On a final note, from Table 4, [13] captured CO from flue gases using Biomass burning tracer CH_3Cl and Industrial tracer C_2Cl_4 . On the other hand, [24] addressed mathematical model of biomass gasification while [26] investigated Power Quality Management Protocol in residential buildings with co-generative capability, with the view of optimization of power usage. This report will be of immense benefit to developing economies that are grappling and tinkering with the possibility of providing adequate power. In another development, [24] and [26] investigated alternative fuel regime (that is butane + propane gas and palm oil respectively) and generation methods to gasoline generators. According to [24], the fuel (that is butane + Propane) consumption by the 10KW micro gas turbo generator at Roma = 0.01kg/s, that is $0.01 \times 60 \times 60 \text{kg/hr} = 36 \text{kg/hr}$. From Table 6, 4.5kg of Butane = US\$27.3. Therefore 0.5kg of Butane = $(27.3/4.5) \times 0.5 = \text{US\$}3.03$. Therefore 0.5kg of Propane = $(26.08/3.9) \times 0.5 = \text{US\$}3.34$. Hence 1kg of gas (that is 0.5kg Butane + 0.5kg Propane) = $\text{US\$}3.03 + \text{US\$}3.34 = \text{US\$}6.37$. But the 10KW micro turbo generator consumes 36kg of mixed gas per hour. Hence the cost of running the 10KW micro turbo generator per hour = $36 \times \text{US\$}6.37 = \text{US\$}229.32$. On the other hand, according to [31], a 10KVA package Gasoline Generator consumes 18litres of petrol in 4.5hours. This implies that this package generator consumes $(18 \text{litres})/4.5 \text{hrs} = 4 \text{litres/hr}$. But from Table 6, [28] posits that a litre of petrol in Nigeria cost US\$0.58. Hence the cost of running this 10KVA Package gasoline generator = $4 \times \text{US\$}0.58 = \text{US\$}2.32$. Comparing the US\$2.32/hr for running this 10KVA package gasoline generator with the US\$229.32/hr for running the 10KW micro turbo generator at Roma, this translates to a cost ratio of 1 to 98.85. The outcome of the Roma project is therefore a very inefficient result against the balance of economics and the background of already available operating generator efficiency in the global market. Consequent on the foregoing, the outcome of the Roma project will not be of immediate benefit as a substitute for package gasoline generators in the developing economies. On the other hand, according to [26], the testing of 20MW Diesel Generator using vegetable oil (that is palm oil) as substitute has some merit. According to [27] from Table 6, the price of palm oil is US\$612 per metric tonne. This is approximately US\$0.612 per litre. Also, according to [29], the price of diesel is US\$3.41 per gallon. This is approximately US\$0.85 per litre. Since the price of palm oil is lower than that of diesel, it makes economic sense to investigate the viability of palm oil as a substitute fuel for the diesel generator. However, the price of petrol in Nigeria according to [28] is US\$0.58 per litre. Against this backdrop, the use of palm oil as a substitute fuel in Nigeria will amount to a bad economic decision.

WHAT FURTHER IMPROVEMENTS NEED TO BE DONE?

From the foregoing, it is evident that much has been achieved in the Legislations, Regulation and Control of flue gases. Much of the emphasis has been directed to the large combustion plants (the "LCP directive"). The volume of research into the capture of SO₂, NO_x, CO and CO₂ from flue gas has been extensive. The implementation of the research outcomes have been so far directed mainly to the LCPs to the detriment of the package generators. The package generators will continue to be relevant in the scheme of economic and domestic activities in the developing economies in as much as the national power grids continue to be epileptic in their service delivery. Therefore, the attendant noise and flue (CO and CO₂ inclusive) pollution will be with the society for a long time to come. The immediate and urgent thing for now is to mitigate and embark on some control measures to limit this pollution to an acceptable statutory level. Hence the need is here now more than ever to incorporate the identified capture technique for SO₂, NO_x, CO and CO₂ into the package gasoline generators. Hence in the design and fabrication of the SO₂, NO_x, CO and CO₂ capture unit, emphasis should be placed on the absorption of the gases using either the wet or dry methods. Some form of sequencing should be done to align capturing process to discarding process in order to optimize the overall system. The outcome of this optimization effort will keep the environment safer and put more money in the pockets of business units, as the environment becomes cleaner, neater and safer hence minimized environmental and pollution litigations, fines and expenses. Also the health and medical bills will drop.

CONCLUSION

The efforts and improvements made in the capture of SO₂, NO_x, CO and CO₂ were never targeted at the gasoline package generators. This appears to be an oversight in the sense that the package generators in the first instance were not actually designed as full time generators. Rather, they were designed to serve as standby and emergency units. But the acute deficit of power supply to economic businesses in developing nations and coupled with poor finances, have compelled the businesses to resort to usage of package generators as main power source. This has led to ample generation of SO₂, NO_x, CO and CO₂, the ODs and GHGs abundantly in the developing countries. Since the use of fossil fuel will remain with us for a long time to come, the need therefore arises for improvement action to be taken in minimizing the emission of the OD and GHGs from the package generators into the environment. The impact of high concentration of CO, CO₂, SO₂ and NO_x to human life is lethal and should not be treated with kid gloves. This severity index is more than enough justification for action to be taken to minimize the attendant scenario that leads to the over generation of these gases. The global position on legislation, regulation and control of Emission Limit Values (ELV) of flue gases has been articulated (that is EU, USA and China). Research efforts and investigations by some previous authors on the capture of SO₂, NO_x, CO and CO₂ from flue gases have been documented herein. The suggested alternative sources of power as substitute for the package gasoline generator by some of the researchers were found to be economically unviable. The review acknowledged the hazard levels of SO₂, NO_x, CO, and CO₂. Currently, no package gasoline generator is fitted with SO₂, NO_x, CO and CO₂ capturing units. The incorporation of these capturing methods in the package gasoline generators will go a long way in reducing the pollution of the environment through flue gases. All efforts directed towards limiting the

indiscriminate and uncontrolled generation of, SO₂, NO_x, CO and CO₂ is a welcome development.

437

438 REFERENCES

- 439 1. Zevenhoven R, Kilpinen. (2001). Green House Gases, Ozone –Depleting Gases.
440 www.abo.fi/~rzevenho/gasbook.html
- 441 2. Norwall. (2010) Norwall Power Systems.
442 <http://www.norwall.com/index.php?cpath=17..>
- 443 3. Okpighie, S.O. (2009). The Effect of Engineering Safety Inspection On The Success of
444 The Power Holding Company of Nigeria's Rehabilitation Projects in the Journal of
445 Engineering and Design. Rosefelt Academic Publications. July 2009; 1(1)Vol. 1 No.
446 1.. Port Harcourt, Nigeria. rap@gmail.com
- 447 4. Citizendium.(2010). Flue Gas---- Encyclopedia Article.
448 http://en.Citizendium.org/wiki/Flue_gas..
- 449 5. Wisegeek.(2010). What Are Flue Gases?.
450 <http://www.wisegeek.com/what-are-flue-gases.htm>.
- 451 6. Emission Limit Values (ELV). (2000): Combustion plants in EU and USA in
452 Legislation on Ambient Air Quality: EU and USA.
453 <http://europa.eu.int/comm/environment/air/legis.htm>
454 <http://ecfr.gpoaccess.gov/cgi/t/textidx?c=ecfr&sid=474f779beade290997e4611971d->
455 -
- 456 7. China Clean Air (2013). "Twelfth Five-Year Plan" on Air Pollution Prevention.
457 www.epa.gov/ogc/china/air%20pollution.pdf
- 458 8. Xie G.; Liu Z.; Zhu Z.; Liu Q.; Ge J. and Huang Z. (2004). Simultaneous Removal of
459 SO₂ and NO_x from Flue Gas Using a CuO/Al₂O₃ Catalyst Sorbent: II. Promotion of
460 SCR Activity by SO₂ at High Temperatures in the Journal of Catalysis. 01/2004
461 DOI:10.1016/j.jcat.2004.02.016.
462 www.researchgate.net/publications/222564682-simultaneous---
- 463 9. Lin, K-Y.A; Petit, C. and Park A-H.A. (2013). *Effect of SO₂ on CO₂ Capture Using*
464 *Liquid-like Nanoparticle Organic Hybrid Materials* in the Journal of Energy Fuels.
465 May 2013, 27 (8), Pp.4167-4174. DOI:10.1021/ef400749.
466 www.Energy.columbia.edu/publications.
467 American Chemical Society Publications (ACS).
- 468 10. Lackner, K.S.; Brennan, S.; Matter, J.; Park, A-H.A.; Wright,A; and Van der Zwaan,
469 BCC. (2012). The Urgency of the Development of CO₂ Capture From Ambient Air in
470 the Proceedings of the National Academy of Sciences, 2012-07-27.
471 www.pnas.org/lookup/suppl/doi:10.1073/pnas.1108765109/-/DCSupplemental.
- 472 11. Chapel D, Ernest J and Mariz C. (1999). Recovery of CO₂ From Flue Gases:
473 Commercial Trends in Conference Proceedings of Society of Chemical Engineers
474 Annual Meeting. Canada. October 4 -6, 1999. Saskatoon, Saskatchewan.
475 www.canadiancleanpowercostition.com/pdf/As10%
476 www.netl.doe.gov/publications/proceedings..
- 477 12. Takaki, K; Iwate, U.; Morioka, J; Shimizu, M.; Sasaki, T and Kato, S. (2003). *Flue*
478 *Gas Treatment Using Dielectric Barrier Discharge With Multipoint Electrode* in the
479 proceedings of 14th IEEE Pulsed Power Conference.Vol.1, Pp. 571-574. 15-18 June
480 2003. Print ISBN: 0-7803-7915-2. INSPEC Accension Number 8529331.
481 DOI:10.1109/ppc.2003.1277776. <http://ieeexplore.ieee.org/>
- 482 13. Wang T.; Cheung, T.F.; Li, Y.S.; Yu, X.M. and Blake D.R.(2002). *Emission*
483 *Characteristics of CO, NO_x, SO₂ And Indications of Biomass Burning Observed At*
484 *a Rural Site in Eastern China* in the Journal of Geophysical Research:
- 485
- 486

- 487 Atmospheres.1984-2012. Vol.107, Issue D12. 29 June 2002.
488 DOI:10.1029/2001JD000724. ACH9-1-ACH-10.
489 [http://onlinelibrary.wiley.com/journal/10.1002/\(ISSN\)2169-8996](http://onlinelibrary.wiley.com/journal/10.1002/(ISSN)2169-8996).
- 490 14. Guagbin, Y.; Chen, J.; Li, J.; Hu, T.; Wang, S. and Lu, H. (2014). *Analysis of SO₂*
491 *And NO_x Emissions Using The Two Fluid Methods Coupled With Eddy Dissipation*
492 *Concept Reaction Submodel in Circulating Fluidized Bed Combustors* in the Journal
493 of Energy and Fuels. 28(3), 2227-2235. February 2014. DOI:10.1021/ef402341p.
494 American Chemical Society. <http://www.researchgate/>
- 495 15. Clay D.T. and Lynn, S. (1975). *Reduction and Removal of SO₂ and NO_x From*
496 *Simulated Flue Gas Using Iron Oxide As Catalyst/Absorbent* in the Journal of
497 American Institute of Chemical Engineers. Vol.21 Issue 3. Pp. 466-473. May 1975
498 First published on line 17 June 2004. DOI:10.1002/aic.690210306
- 499 16. Fudong L.; Asakura K.; He, H.; Shan, W.; Shi, X. and Zhang, C.(2011). *Influence of*
500 *Sulfation on Iron Titanate Catalyst For the Selective Catalytic Reduction of NO_x With*
501 *NH₃ in the Medium Temperature Range* in the Journal of Applied Catalysis B-
502 Environmental. January 2011. 103(3). 369-377. DOI:10.1016/j.apcatb.2011.01.044
- 503 17. Fudong L.; He, H. and Zhang, C.(2008). *Novel Iron Titanate Catalyst for The*
504 *Selective Catalytic Reduction of NO With NH₃ in The Medium Temperature Range*
505 in the Journal of Chemical Communications. Issue 17. 20 June 2008.
- 506 18. Bienstock, D.; Field, J.H. and Myers, J.G. (1964). *Discussion: "Removal of Sulfur*
507 *Oxides From Flue Gas With Alkalized Alumina at Elevated Temperatures* in the
508 ASME Journal of Engineering for Gas Turbines and Power. Vol. 86, Issue 3, Pp.
509 353-358.1964. Online 10 January 2012. Doi:10.1115/13677603.
510 <http://gasturbinespower.asmedigitalcollection.asme.org/article>.
- 511 19. Reid, W.T. (1970). *Basic Factors in The Capture of Sulfur Dioxide By Limestone*
512 *and Dolomite* in the ASME DC/ Journal of Engineering For Gas Turbines and Power.
513 92, Pp.11-16. www.gasturbinespower.asmedigitalcollection.asme.org/article.
- 514 20. Siagi, Z.O. and Mbarawa, M. (2007). *Experimental Investigation of The SO₂*
515 *Abatement Capacity of South African Calcium-Based Materials—in the Proceedings*
516 *of The ASME 2007 Energy Sustainability Conference, Long Beach, California*. 27-
517 30 July 2007. Pp. 121-126. ISBN; 0-7918-4797-7. eISBN: 0-7918-3798-x.
518 DOI:10.1115/ES2007-36141.
519 www.proceedings.asmedigitalcollection.asme.org/proceeding
- 520 21. PRNNewswire (2014). *Global Industrial Flue Gas Treatment Systems and Services*.
521 Dublin, 01 may 2014 [http://www.prnewswire.com/news-releases/global-industrial-](http://www.prnewswire.com/news-releases/global-industrial-flue-gas-treatment-systems-services-fgd-denox)
522 [flue-gas-treatment-systems-services-fgd-denox](http://www.prnewswire.com/news-releases/global-industrial-flue-gas-treatment-systems-services-fgd-denox).
- 523 22. Researchmoz. (2014). *Global and China Flue Gas Desulfurization System Industry*.
524 Published: 2014-02-28. P.163.
525 www.researchmoz.us/global-and-china-flue-gas-desulfuriz---
- 526 23. Capata, R. and Veroli, M. (2012). *Mathematical Modeling of Biomass Gasification in*
527 *a Circulating Fluidized Bed (CFB) Reactor* in the Journal of Sustainable Bioenergy
528 Systems (JSBS). Vol. 2 NO. 4. 2012. Pp. 160-169. DOI:10.4326/jsbs.2012.24022.
529 www.scirp.org/journal/paperinformation.aspx?paperID=26036
- 530 24. Calabria, A.; Capata, R.; Veroli, M. and Pepe G. (2013). *Testing of the Ultra-Micro*
531 *Gas Turbine Devices (1 ~ 10 KW) For Portable Power Generation* at University of
532 Roma 1: First Test Results. 6 April 2013. Engineering, 2013, 5, 481-489.
533 <http://dx.doi.org/10.4236/eng.2013.55058>. published online May 2013.
534 www.downloadily.com/docs/mit-s-micro-gas-turbine-engine.html .
535 Hosted by www.scirp.org.
- 536 25. Veroli, M. and Calabria, A. (2012). *A Proposal For Power Quality Management*
537 *Protocol in Residential Buildings With Co-generative and Renewable Systems* in the
538 Proceedings of ASME 2012 International Mechanical Engineering Congress and
539 Exposition. Vol. 10: Emerging Technologies and Topics Public policy. Houston,

540 [Texas, USA. 9-15 November 2012. ISBN: 978-0-7918-4526-4. Paper NO.](#)
 541 [IMECE2012-85583. Pp. 99-105. Doi:10.1115/IMECE2012-85583.](#)
 542 [www.proceedings.asmedigitalcollection.asme.org/proceedings--](#)
 543 26. Capata, R. and Calabria, A. (2012). *Power Generation With Vegetable Oils in The*
 544 *Italian Scenario: A 20MW Case Study: Technical Feasibility Analysis and Economic*
 545 *Aspects* in the *Proceedings of the ASME-IMECE2011 Conference. VOL. 4 No. 9*
 546 *Part A.* [www.proceedings.asmedigitalcollection.asme.org/pdfaccess.55ht](#)
 547
 548 27. Mathes and Porton Bhd. (2014). Malaysian AM Cash Market Prices for Palm Oil.
 549 August 29, 2014.12.55 UTC+8. <http://www.palmoilliq.com/palm-oil-plantation-stocks>.
 550 28. KSitij. (2014). Comparison of Global Petrol Prices Across the World With India. 30
 551 August 2014. <http://kshitij.com/re-2014-prices>.
 552 29. Webcrawler. (2014). Gas Prices in World Market. WJXT Jacksonville. 30 August
 553 2014. www.webcrawler.com
 554 30. Confusedaboutenergy. (2014). Fuel Prices – Confused About Energy?: Butane and
 555 Propane. <http://www.confusedaboutenergy.co.uk/index.php--fuel/fuel-prices>.
 556 31. Genpower. (2014). Honda, Robin, Kohler and Briggs & Stramon Petrol Generators.
 557 Gp10000 EGX, AVR, 10KVA, 230V, GX630. 08 September 2014.
 558 www.genpower.co.za/generators.
 559
 560